

OPA



February 24, 1994

Mr. Delin Crofts
Naples Truck Stop
1500 East 1625 South
Naples, Utah 84078

Dear Mr. Crofts,

This letter is to verify that I conducted a precision tightness test on 3 product lines at the Naples Truck Stop on February 13, 1994. The products tested were premium unleaded, unleaded and unleaded plus.

After isolating the tanks from the lines, I applied 50 pounds per square inch of pressure to the line. I used the Horner Ezy Chek volumetric test method.

From the testing I conducted I concluded that the unleaded plus and the premium unleaded lines were tight and the unleaded line had a leak in it.

Sincerely,

A handwritten signature in cursive script.

Kenneth R. Wheeler
UT-0055

FILED
92.05.05